CERTIFICATE

FOR EUROPEAN PRODUCT SAFETY

Reference No. SE-S-2300703

Miniature fuse-link

Type designation: 505

Certificate holder: Littelfuse Inc.
O'Hare Plaza II Ste 500, 8755 W. Higgins Rd.
Chicago IL 60631
UNITED STATES OF AMERICA

The product complies with the standard(s): EN 60127-1:2006+A1+A2
EN 60127-7:2016

Date of expiry: 17 November, 2028

EU Directive information: According to the principle of presumption of conformity, this certificate constitutes support for an EU Declaration of Conformity to the Low Voltage Directive 2014/35/EU.

Additional information in Appendix

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed: **Date:** 21 June, 2023

Quan Li

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX:

Reference No. SE-S-2300703

Technical Data:

Type designation	505
Rated voltage (V)	450 VAC
Rated current (A)	10A; 12A
Trademark	LF.
Test Report	2300166STO-001
Product information	Quick-acting. Size 6,3 x 32 mm. Pre-arcing time/current characteristic: according to manufacturer's specification. Maximum voltage drop max.380 mV Maximum sustained power dissipation: max. 5,5 W Breaking capacity: 20kA at 450 VAC, power factor > 0,98 With or without wire terminations (pigtails).

Manufacturing Sites: Suzhou Littelfuse OVS Ltd.
6 Xinghai Street, Suzhou Industrial Park, Suzhou City
Jiangsu Province 215021
CHINA

According to the principle of presumption of conformity, this certificate, which includes production control, constitutes support for an EU Declaration of Conformity according to the Low Voltage Directive 2014/35/EU. This presumption can expire before end of validity of this certificate due to new issued Standard or Amendment and changes within the EU legislation.

This certificate replaces previously issued ref. No. 1620079 dated 09 May 2017. A new certificate has been issued on account of renewal testing.

Certification Body: Intertek Semko AB, Product Certification **Place:** Kista - Stockholm

Signed: **Date:** 21 June, 2023

Quan Li

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.