

## UK-TYPE EXAMINATION CERTIFICATE

Component Intended for use on/in a Product or Protective System Intended for use in  
Potentially Explosive Atmospheres  
UKSI 2016:1107 (as amended) – Schedule 3A, Part 1

- UK-Type Examination Certificate Number: **BAS21UKEX0085U**
- Product: **259 Series Safe-T-Plus Fuse**
- Manufacturer: **Littelfuse Philippines Incorporated**
- Address: **Lima Technology Centre, Special Economic Zone, Lipa City, Malvar, Batangas, Philippines 4233**
- This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.
- SGS Baseefa, Approved Body number 1180, in accordance with Regulation 43 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended), certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.
- The examination and test results are recorded in confidential Report No. **21(C)0103**
- Compliance with the Essential Health and Safety Requirements has been assured by compliance with:
- EN IEC 60079-0:2018 EN 60079-11:2012**
- except in respect of those requirements listed at item 18 of the Schedule.
- The sign “U” is placed after the certificate number. It indicates that this certificate must not be mistaken for a certificate intended for an equipment or protective system. This partial certification may be used as the basis for certification of an equipment or protective system.
- This UK-TYPE EXAMINATION CERTIFICATE relates only to the design and construction of the specified product. Further requirements of the Regulations apply to the manufacturing process and supply of this product. These are not covered by this certificate.
- The marking of the product shall include the following:

 **II 1 G Ex**

SGS Baseefa Customer Reference No. **5095**

Project File No. **21/0103**

This document is issued by the Company subject to its General Conditions for Certification Services accessible at <http://www.sgs.com/en/Terms-and-Conditions.aspx> and the Supplementary Terms and Conditions accessible at <http://www.sgs.com/SGSBaseefa/Terms-and-Conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained herein reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. It does not necessarily indicate that the equipment may be used in particular industries or circumstances. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, schedule included, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

### SGS Baseefa Limited

Rockhead Business Park, Staden Lane,  
Buxton, Derbyshire SK17 9RZ

Telephone +44 (0) 1298 766600 Fax +44 (0) 1298 766601  
e-mail [baseefa@sgs.com](mailto:baseefa@sgs.com) web site [www.sgs.co.uk/sgsbaseefa](http://www.sgs.co.uk/sgsbaseefa)

Registered in England No. 4305578.

Registered address: Rossmore Business Park, Ellesmere Port, Cheshire, CH65  
3EN



(pp)

R S SINCLAIR  
TECHNICAL MANAGER  
On behalf of SGS Baseefa  
Limited

13

## Schedule

14

Certificate Number BAS21UKEX0085U

### 15 Description of Product

The 259 Series Safe-T-Plus fuse is a range of fuses encapsulated to a minimum depth of 2mm (3mm typically) for use in intrinsically safe apparatus. The encapsulation material is Polyamide 6 which is stated by the manufacturer of the material to have a CTI greater than 175.

The leads are separated by a minimum creepage and clearance distance of 9mm.

The range of fuses covered by this Certificate, together with the minimum cold fuse resistance at -20°C and -40°C, is as follows:

Catalogue Number		Rating	Resistance ( $\Omega$ )	
Yellow	Green		-20°C	-40°C
259.062xx	259.062xx913	62mA	4.89	4.39
259.125xx	259.125xx913	125mA	1.35	1.26
259.250xx	259.250xx913	250mA	0.51	0.48
259.375xx	259.375xx913	375mA	0.32	0.29
259.500xx	259.500xx913	500mA	0.24	0.22
259.750xx	259.750xx913	750mA	0.14	0.12
259001xx	259001xx913	1A	0.10	0.07
259003xx	259003xx913	3A	0.03	0.01
259005xx	259005xx913	5A	0.01	0.005

xx denotes supply packaging

The fuse is suitable for installation in equipment with Equipment Protection Level (EPL) Ga.

### 16 Report Number

21(C)0103

### 17 Specific Conditions of Use

- The fuse must be mounted so as to ensure the creepage and clearance distances are not impaired in any way.
- The fuse is suitable for use in intrinsically safe equipment for voltages not exceeding 190V peak.
- When used in intrinsically safe equipment, it will be necessary to determine a surface temperature classification for the fuse:

<i>Fuse Rating</i>	<i>Maximum surface temp rise (at 1.7I<sub>n</sub>)</i>
≤ 750mA	40°C
1A	55°C
3A	118°C
5A	135°C

## **18 Essential Health and Safety Requirements**

In addition to the Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9, the following are considered relevant to this product:

<b>Clause</b>	<b>Subject</b>	<b>Compliance</b>
13	Protection against other hazards (LVD type requirements, etc.)	Manufacturer responsibility
14	Overloading of equipment (protection relays, etc.)	User/Installer responsibility
22(1)	External effects	User/Installer responsibility
22(2)	Aggressive substances, etc.	User/Installer responsibility

## **19 Drawings and Documents**

<b>Number</b>	<b>Sheet</b>	<b>Issue</b>	<b>Date</b>	<b>Description</b>
0259000	1 of 1	U	12.20.21	Quick Act Fuse (Safe-T-Plus)

This drawing is common to Baseefa02ATEX0071U and IECEx BAS 10.0098U