



Effective Date: February 2021

This listing is subject to re-examination in one year.

www.icc-es-pmg.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

CSI: DIVISION: 22 00 00—PLUMBING
Section: 22 13 16—Sanitary Waste and Vent Piping

Product certification system:

The ICC-ES product certification system includes testing samples taken from the market or supplier's stock, or a combination of both, to verify compliance with applicable codes and standards. The system also involves factory inspections, and assessment and surveillance of the supplier's quality system.

Product: SureSeal® - Barrier Type Floor Drain Trap Seal Protection Devices ("Device")

Listee: RectorSeal, LLC
2601 Spenwick Drive
Houston, Texas 77055
www.rectorseal.com

Compliance with the following codes:

2021, 2018, 2015, 2012, 2009 and 2006 *International Plumbing Code*® (IPC)
2021, 2018, 2015, 2012, 2009 and 2006 *International Residential Code*® (IRC)
2021, 2018, 2015, 2012, 2009 and 2006 *National Standard Plumbing Code*® (NSPC)
2021, 2018, 2015, 2012, 2009 and 2006 *Uniform Plumbing Code*® (UPC)*

*Copyrighted publication of the International Association of Plumbing and Mechanical Officials

Compliance with the following standards:

ASSE 1072-2020, Performance Requirements for Barrier Type Floor Drain Trap Seal Protection Devices, American Society of Sanitary Engineering.
ICC-ES LC1015, PMG Listing Criteria for Elastomeric, Normally Closed, Floor Drain Evaporation Resistant Sealing System (Oct 2010)

Identification:

The product and/or package must bear the SureSeal® name, the model number and the ICC-ES PMG listing mark.

Installation:

SureSeal® trap primer alternates are to be installed in accordance with the manufacturer's instructions and the applicable code.

Models:

<u>MODEL</u>	Device SIZE		FLOW RATE	
	<u>Inches</u>	<u>mm DN</u>	<u>GPM</u>	<u>L/M</u>
SS2009V	2	40	12.0	45.4
SS3009V	3	50	34.0	128.7
SS3509V	3½	80	52.0	196.6
SS4009V	4	100	73.0	276.4
SS2009Plus	2	40	12.0	45.4
SS3009Plus	3	50	34.0	128.7
SS4009Plus	4	100	73.0	276.4

Conditions of listing:

1. SureSeal® devices, recognized by this listing, are intended to serve as alternates to the code-required trap primer. They must serve a functioning trap.
2. The plumbing systems must be installed in accordance with the applicable codes.
3. The "Device" must be accessible.
4. SureSeal® trap primer alternates are manufactured under a quality control program with annual surveillance inspections.