



Department of Safety and Professional Services
Division of Industry Services
Plumbing Product Review
4822 Madison Yards Way
P.O. Box 7162
Madison, Wisconsin 53707-7162
Phone 608-266-2112
Web <http://dsps.wi.gov>
Email dsps@wisconsin.gov
TTY: Contact Through Relay

Governor Tony Evers Dawn Crim, Secretary

May 25, 2021

Rectorseal LLC
Kathleen Kelch
2601 Spenwick Dr.
Houston TX 77055

Re: Description: Solvent Cement
Manufacturer: Rectorseal LLC
Product Name: Arctic 616L: 55900, 55909, 55919, 55948 and 55953
Model Number(s): Arctic 616L: 55900, 55909, 55919, 55948 and 55953
eSLA PTO No.: PP-052100010-PTOAA

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. SPS 384.40 (14) (b) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of May 2026.

This approval supersedes the approval issued on May 11, 2016 under product file number PP-051603533-PTOAA.

This alternate approval is contingent upon compliance with the following stipulation(s):

1. This solvent cement shall be used in strict accordance with the manufacturer's published instructions, Chapters 381-387 Wis. Adm. Code and this product approval. If there is a conflict between the manufacturer's instructions and the Wis. Adm. Code or this Plumbing Product Approval, then the Wis. Adm. Code and this Plumbing Product Approval shall take precedence.
2. This solvent cement may be used on PVC gravity flow DWV and potable cold water PVC piping pipe without primer.
3. For the duration of this approval, the manufacturer shall maintain conformance of this solvent cement to ASTM D2564;
4. Users of this solvent cement, professionals in particular, shall read the SDS sheet for these products.

Technical notations:

- a. Manufacturer's website: <https://rectorseal.com/arctic-616l-group/>

The department is in no way endorsing this product or any advertising and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlüter
Plumbing Product Reviewer-Standards Administrator
Department of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 **Phone**
glen.schlueter@wi.gov **E-mail**
7:45AM-4:30PM CDT M-F **Work Hours**