



Copy: Scott Hix
John Tolbert
JC Powers
Barry Rust

11/13/2013
Dwight Butler
A/C LEAK FREEZE
5626 Southwestern Blvd.
Baltimore, MD 21227
www.leakfreeze.com

Dear Dwight:

The following two compressors have completed our life testing using R410A and POE oil. Test condition was start stop at 55°F evaporator 155°F condensing, 156 psig suction pressure and 645 discharge pressure, 2 minutes on 10 seconds off.

Compressor Model	CID No.	Total Cycles	Total Hours
H82J37BABCA	28797	98,870	3,583
H82J50BABCA	24346	100,000	3,588

- Our testing has not produced any failures or abnormal wear using the subject products
- We have 19 field test sites on going with no issues
- LEAKFREEZE used in our compressors in accordance with the manufacturer's instructions will not void the compressors warranty

Sincerely,

A handwritten signature in cursive script that reads "Larry G. Pippin".

Senior field Service Engineer



Larry Pippin
Senior Field Service Engineer
Bristol Compressors
15185 Industrial Park Road, Bristol, VA 24202
276-645-2458 office, 276-645-7561 fax
Larry.pippin@bristolcompressors.com